

## Ratnagiri Gas & Power Private Limited (RGPPL)

NIT No.: RGPPL/C&M/Purchase/OT-25

Date: 13/04/2019

Sub: Procurement of HT Cables.

## Corrigendum-01

With reference to our Tender Enquiry No.: RGPPL/C&M/Purchase/OT-25 dated 08/02/2019, following modifications are incorporated in Tender Document:

a. **Technical Specifications:** For item code no.s 8110553142, 8110554174 and 8110554208, the technical specifications sr. no. 8

"Armour shall be flat strip galvanized steel as per IS 3975 (1970) with latest amendments"

Shall be read as

"Armour shall be of Non-magnetic material as per IS 7098 (Part 2): 2011 with latest amendments". Qualifying requirements are same, additional checklist for QR added.

All other terms and conditions of original tender document shall remain unaltered.

Thanking you,

Yours faithfully For & on Behalf of RGPPL

Manager (C&M)

