



Enquiry No.: 221300049

Sub: Biennial contract for painting on supply and apply basis for Power Block/ BOP area mechanical equipments at RGPPPL.

RGPPPL		<u>NAME OF WORK: SUPPLY & APPLY OF PAINT ON MECHANICAL EQUIPMENTS /Structures & SYSTEMS AT RGPPPL</u>				QUALITY PLAN		A:CRITICAL B:MAJOR C:MINOR	
						LOA/PO. NO. /dated:		PAGE NO.: 1 OF 1	
						YOUR REF./dated:			
SL. NO.	ITEMS /STAGE AND CHARACTERISTICS TO BE CHECKED	TYPE OF CHECK	METHOD OF CHECK	FREQUENCY	RELATED SPECIFICATN & ACCEPTNCE NORMS	FORMAT OF RECORD	A/ B/ C	REMARKS	
I	II	III	IV	V	VI	VII	VIII	IX	
1	All type of paint & primer (Contractor supply)	Brand, batch no. & shelf life	Physical verification	100%	NTPC specifications	Manufacturer's test certificate	A + B	Party to submit manufacturer's test certificate of supplied primer / paint	
2	Surface preparation / cleaning	Physical	Visual	100%	NTPC specifications	---	B	Surface preparation to St3 grade or as given in scope of work	
3	Painting with suitable paint	Physical	Visual	100%	NTPC specifications	---	B	Painting with primer / paint as given in painting schedule	
4	Letter writing / arrow marking	Physical	Visual	100%	NTPC specifications	---	B	Letter writing / arrow marking as per instructions of EIC / area engineer	


Corporate Identification Number: U40105DL2005 PTC138458

Registered Office : NTPC Bhawan, Core-7, SCOPE Complex 7, Institutional Area, Lodi Road, New Delhi 110003

Noida Office : The Landmark, Second Floor, Plot No. A35, Sector 2, Noida-201301 (U.P), Tel: 0120- 4148900, Fax: 0120-4148913

Mumbai Office : Samruddhi Venture Park, 5th Floor, MIDC, Marol, Andheri (E), Mumbai - 400093. Tel: 022- 28216613, Fax: 022-28269057

Project Site : PO RGPPPL Anjanwel, Taluka Guhagar, Distt. Ratnagiri (Maharashtra) 415634, Tel: 02359- 241073, Fax: 02359- 24111





Enquiry No.: 221300049

Sub: Biennial contract for painting on supply and apply basis for Power Block/ BOP area mechanical equipments at RGPPPL.

5	Spillage cleaning	Physical	Visual	100%	NTPC specifications	---	B	---
6	DFT measuring instrument	Calibration certificate	Physical verification	100%	Govt. / NABL approved lab	-	A + B	Party to submit valid calibration certificate
7	Dry film thickness (DFT) measurement after completion of one area / section	Physical	Measurement by Elcometer	Test patches	Min. DFT of particular primer / paint as given in painting schedule	DFT measurement sheet	A + B	If required DFT not achieved then additional coat has to be done to get required thickness.

Note: It is the responsibility of the contracting agency to offer 'A' class checks to witness by FQA & 'B' class checks to witness by execution department.

	CONTRACTOR	MECHANICAL MAINTENANCE	FQA
SIGNATURE			
Name/Designation			

Corporate Identification Number: U40105DL2005 PTC138458

Registered Office : NTPC Bhawan, Core-7, SCOPE Complex 7, Institutional Area, Lodi Road, New Delhi 110003

Noida Office : The Landmark, Second Floor, Plot No. A35, Sector 2, Noida-201301 (U.P), Tel: 0120- 4148900, Fax: 0120-4148913

Mumbai Office : Samruddhi Venture Park, 5th Floor, MIDC, Marol, Andheri (E), Mumbai - 400093. Tel: 022- 28216613, Fax: 022-28269057

Project Site : PO RGPPPL Anjanwel, Taluka Guhagar, Distt. Ratnagiri (Maharashtra) 415634, Tel: 02359- 241073, Fax: 02359- 24111

